

CITY OF SULPHUR SPRINGS  
CONSTRUCTION BOARD OF ADJUSTMENTS & APPEALS  
MEETING  
DECEMBER 8, 2008

Meeting of the Sulphur Springs Construction Board of Adjustments and Appeals was conducted in the Municipal Building at 125 S. Davis Street at 5:10 P.M.. The meeting was called to order by Chairman John Cooper, with the following members present:

Chairman John Cooper  
Rickey Payne  
Winston Sawyer  
Wayne Cooper  
Scott Tubb

Staff: Travis Crump, Chief Building Official  
Johnny Vance, Dir. Community Dev.  
Audine Turman, Secretary CBAA

**DISCUSSION/ACTION MEETING MINUTES 3/15/04:**

Motion made by Winston Sawyer and seconded by Rickey Payne to approve Construction Board of Adjustments and Appeals minutes of March 15, 2004 as written. Motion carried, all voting aye.

**DISCUSSION/ACTION REQUEST BY ROBERT SQUIBB TO USE CPVC:**

A hearing was conducted to discuss a request by Robert Squibb to use CPVC instead of copper for the piping above the slab at 1414 College Street, being further described as Lot 1, Block 311. The Sulphur Springs Building Inspections has uniformly and consistently enforced the provision that all water lines inside a structure be copper. The use of Polybutylene plastic piping (also known as Cross-Linked Polybutylene, PEX, PEX-AL-PEX, or PE-AL-PE), PVC OR CPVC piping is not allowed in the City of Sulphur Springs as a plumbing method inside a structure. After discussion, a motion to deny the request was made by Wayne Cooper and seconded by Scott Tubb. Motion carried, all voting aye.

**ANY OTHER BUSINESS & ADJOURN:**

With no other business, the Chairman adjourned the meeting at 5:20 P.M..